

Jurong Port Pte Ltd  
37 Jurong Port Road  
Singapore 619110

telephone (65) 6265 0666  
facsimile (65) 6265 6614  
web site www.jp.com.sg

No. 30 of 2017

28<sup>th</sup> April 2017

To: Tenants and leases

**Safety Bulletin Issue 1 – FY 2017 : Fire Safety Non Compliance**

1. Please refer to the attached Safety Bulletin Issue 1.
2. We would like to urge all tenants and leases to comply with Fire Safety Act for your premises. Tenants and leases may be sanctioned under Jurong Port's Demerit Point Scheme (DPS) if non compliances are found during the Arson Prevention Inspection at your premises.
3. Kindly also disseminate the said information.

Thank you.

Sim Chear Wah  
Vice President  
Workplace Safety & Health  
Jurong Port Pte Ltd

For updates on safety-related news and information, please visit [www.wshc.sg](http://www.wshc.sg)

## Fire Safety Hazards

### Arson Prevention Inspection

JP's Workplace, Safety & Health (WSH) department have conducted several fire safety inspections at various locations such as tenanted warehouses, offices and leased areas. Several fire safety hazards which are in violation of Fire Safety Act have been identified at the workplaces as shown below.

#### Obstruction to fire extinguisher



#### Obstruction to fire hose reel



#### Obstruction to fire exit



#### Obstruction to fire escape route



### Corrective Measures

WSH department urges all tenants and leasees to comply with the Fire Safety Act and take immediate corrective action(s) if your workplace has any of the above fire safety infringements. Tenants and Leasees may be sanctioned under JP's Demerit Point Scheme (DPS) if non-compliances are found during the Arson Prevention Inspection at your premises.